


# Compilation of the SANIRESCH-Factsheets

This compilation contains the factsheets of the MAP (struvite) reactor and the greywater as well as the brownwater treatment plant installed within the SANIRESCH project. The factsheets provide a detailed overview regarding technical aspects, analysis results and energy as well as investment costs.

Magnesium-Ammonium-Phosphate (MAP) reactor.....	Page 2
Brownwater treatment (membrane bioreactor).....	Page 5
Greywater treatment (membrane bioreactor).....	Page 8
General project information.....	Page 12



This figure illustrates the SANIRESCH concept:

Urine is stored temporarily in tanks. Later, struvite is precipitated in the MAP reactor and both, urine and struvite can be used as a fertiliser in agriculture. A part of the brownwater is treated by the membrane bioreactor and can be used as service water. The solids could be used after composting as a fertiliser in agriculture. The greywater from tea kitchens and hand wash basins is treated in a MBR as well and the permeate is used as service water for the brownwater pretreatment plant.

The red boxes mark the plants which are presented in these factsheets.

# Magnesium-Ammonium-Phosphate (MAP) reactor

1 - NoMix toilet



2 - Urine tank



3 - Dosing unit



4



4 - Magnesium oxide


6 - Filter bags



7



7 - Struvite



5 - Precipitation tank (with stirrer)

SPONSORED BY THE



Federal Ministry of Education and Research



# Magnesium-Ammonium-Phosphate (MAP) reactor

## 1 Process principle

Simplified equation:



Ammonium ( $\text{NH}_4^+$ ):  
Magnesium ( $\text{Mg}^{2+}$ ):

Ammonium ion, available in excess in urine  
Magnesium ion, develops in the reaction chamber of the added MgO (magnesium oxide)

Phosphate ( $\text{PO}_4^{3-}$ ):  
MAP ( $\text{MgNH}_4\text{PO}_4$ ):

Phosphate ion, present dissolved in urine  
Reaction product (also known as struvite)

## 2 Process technology

### 2.1 Removal of nutrients

$P_{\text{total}}$ in influent:	180 mg/l (average)
$P_{\text{total}}$ in effluent:	36 - 72 mg/l
P removal:	60 - 80 %
$N_{\text{total}}$ in influent:	2700 mg/l
$N_{\text{total}}$ in effluent:	540 – 1080 mg/l
N removal:	60 - 80 % (Probably mainly due to ventilation)

### 2.2 Cycle data and amount of urine

10 cycles per day	
Duration of one cycle:	135 min
Urine flow rate:	171 l/d
Per cycle:	40 l (theoretically possible: 50 l)
Amount treated:	400 l/d (theoretically possible: 500 l/d)
Usable urine storage:	7.5 m <sup>3</sup> (in 4 storage tanks)
Duration to process 7.5 m <sup>3</sup> :	4 weeks if operating at 5 days per week and at full load

## 3 MAP recovery

MAP recovery:	
➤ with technical grade MgO	50 - 65 %
➤ with analytical grade MgO	90 - 95 % (only a few experiments in the laboratory)
Estimated recovery:	0.8 g MAP <sub>dried</sub> / l urine
MAP production with technical MgO:	263 g MAP/d 69 kg MAP/year

# Magnesium-Ammonium-Phosphate (MAP) reactor

## 4 Operating costs

MgO bag:

- Total material costs 0.31 €/bag
- Bag material polyvinyl alcohol
- Bag content 14 g MgO/bag (for cycle with 40 l urine)

Needle felt filter:

- Costs 3 €/filter bag
- Life time single use
- MAP loss 37 - 12 % (remains in the filter)

Nylon filter (alternative option):

- Costs 45 €/filter bag (only a few experiments)
- MAP loss negligible loss

World market price MAP: approx. 300 €/t (conservative estimate)

Value of the produced MAP: 21 €/year

Theoretical costs (€) to fertilise 1 ha summer wheat for one year:<sup>1</sup>

Urine	MAP (Pilot plant)	NPK (Mineral fertiliser)
560	112,000,-	120

Reason for the high MAP costs:

- 1) at the moment there is a lot of manual labour necessary to produce MAP
- 2) MAP reactor was a new development, therefore very high investments cost

## 5 Field tests near Bonn

Soil:

Supply level C (nutrient-rich soil)

Fertiliser:

100 - 140 kg N/ha for summer wheat, 40 kg N/ha for miscanthus

Urine application:

3-4 l/m<sup>2</sup> or 30-40 m<sup>3</sup>/ha (see table)

Date comparison:

	Data from Bonn	Technology Review <sup>2</sup>
N concentration in urine (gN/l)	2.3 – 3.9	maximum 7
Amount per area (l/m <sup>2</sup> )	3 – 4	1.5
N content per area (kgN/ha)	70 – 100	maximum 105

<sup>1</sup> Braum, C. (2011). Economical feasibility of using urine versus struvite as fertilizer. Using the example of GIZ in Eschborn. Bachelor thesis. Institute of Soil Sciences and Soil Conservation, Justus Liebig University Gießen, Germany  
<http://www.saniresch.de/images/stories/downloads/Bachelor%20Thesis%20Christina%20Braum.pdf>

<sup>2</sup> von Muench, E., Winker, M. (2011). Technology review of urine diversion components - Overview on urine diversion components such as waterless urinals, urine diversion toilets, urine storage and reuse systems. Gesellschaft für Internationale Zusammenarbeit (GIZ) GmbH, Eschborn, Germany.  
<http://www.susana.org/lang-en/library?view=ccbctypeitem&type=2&id=875>




# SANIRESCH - Greywater treatment plant (MBR)

Collection tank

Membrane bioreactor

Storage tank

Remote control




**1 - Raw greywater**  
 COD 450 - 1000 mg/l



**2 - Preceding screen (3 mm)**



**3 - Aeration blowers**




**4 - Ultrafiltration module**  
 Plate membrane 3.5 m<sup>2</sup> / pore size 38 nm



**5 - Membrane bioreactor (MBR)**  
 Volume of tank 480l



**6 - Permeate**  
 280 l/day  
 COD < 30 mg/l



**Control panel**

## 1. Technology

Source of greywater:	7 kitchenettes with sinks and dishwashers, 2 sinks, 19 hand washbasins in toilets rooms, 10 washbasins for cleaning purposes
Greywater inflow <sub>average</sub> :	approx. 500 - 600 l/d
Flowrate of permeate <sub>average</sub> :	approx. 300 l/d

### 1.1 Volume

Pretreatment tank:	480 l
Membrane bioreactor <sub>average</sub> :	440 l (controlled by COD, TS and throughput)
Tank for service water:	480 l

### 1.2 Pretreatment

Mesh size of sieve:	3 mm
Cleaning of filter unit:	3 times per day for 10 s
Aeration of collection tank:	30 s/h (for mixing)
SS in filtrate:	100 - 150 mg/l

### 1.3 Membrane filtration module

Type of membrane:	Plate membrane (MembranClearBox®)
Membrane surface & pore size:	3.5 m <sup>2</sup> , 38 nm
Material of membrane:	PES (Polyethylensulfon)
Scouring air <sub>regular</sub> :	continuously
Scouring air <sub>energy saving</sub> :	60 s operation, 60 s break
Aeration <sub>regular</sub> :	60 s operation, 60 s break
Aeration <sub>energy saving</sub> :	60 s operation, 360 s break
Oxygen concentration:	8.1 mg/l
MBR feeding pump:	Automatically regulated according to filling level of MBR
Permeate pump:	20 h/d filtration: 270 s operation, 120 s break 4 h/d relaxation (no operation)
Operation of permeate pump <sub>overall</sub> :	20 h/d
Operation of permeate pump <sub>net</sub> :	14 h/d (taking breaks into account)
Flowrate of permeate:	22 l/h; equivalent 300 l/d (14 h of operation)
Transmembrane pressure <sub>net</sub> :	
➤ average	-60 mbar
➤ maximum possible	-350 mbar
Flux <sub>net</sub> :	(Flow rate of permeate through membrane)
➤ average	6 l/(h x m <sup>2</sup> )
➤ maximum possible	30 l/(h x m <sup>2</sup> )
Concentration of activated sludge:	4 - 6 g TS /l
Removal of surplus sludge:	40 l/week (automatically)

## 2. Analyses\*

	COD (mg/l)	N <sub>total</sub> (mg/l)	NO <sub>3</sub> -N (mg/l)	NH <sub>4</sub> -N (mg/l)	P <sub>total</sub> (mg/l)
<b>Inflow</b>	590 ± 170	14 ± 5.0	0.5 ± 0.2	0.4 ± 0.3	23 ± 14
<b>Permeate</b>	27 ± 5.5	12 ± 3.7	7.7 ± 2.6	0.01 ± 0	16 ± 3.1

\* Concentrations with 95% confidence intervals.

COD-removal efficiency:  
95 %

Nutrient ratios in inflow:  
C : N : P = 100 : 2.1 : 5.2

Effect of dishwasher tabs:

P <sub>total</sub> - content (mg/l)	Inflow	Permeate
<b>Containing phosphate</b>	35 ± 7.7	16 ± 3.3
<b>Not containing phosphate</b>	16 ± 10	16 ± 3.1

## 3. Use of permeate

Possible areas of application:  
(Complying with quality standards e.g.  
EU Bathing water directive)

Process water for toilet flushing, heating,  
air conditioning, wash machines, irrigation

Uses in GIZ:

Scouring for the pre-treatment of the  
brownwater plant

## 4. Time spent on operation

The standard operation requires one scheduled maintenance event per year at which time an effluent sampling can also be analysed. Due to the research activities the time consumption is calculated as follows:

Maintenance: 2 days every six months  
Analysis: 3 - 4 h/week  
Control of operation: 3 h (divided over 2 days per week)

## 5. Energy consumption

The energy consumption is related to the plant component membrane bioreactor (see figure). These are design values, because no measures were done. The energy consumption can be higher than normal due to research activities.

Energy consumption: 1.2 kWh/d (equivalent to 455 kWh/a)  
Specific energy consumption: 2.1 kWh/m<sup>3</sup>  
Energy costs: 90 €/a (0.20 €/kWh)

## 6. Investment costs (without pretreatment)

Container, plant unit, control unit,  
membrane module 5,990 € (net, ex factory)



# SANIRESCH – Brownwater treatment plant



**1 - Brownwater**  
 From NoMix toilets: ~ 2000 l/d



**2 - Screen basket with screw**  
 For solids separation (hole size: 3 mm)




**3 - Pretreatment tank**  
 Volume of tank: ~ 400 l

## Pretreatment/ collection tank

## Membrane bioreactor


## Remote control



Control panel touch screen



**4 - Membrane bioreactor**  
 Volume of tank: 710 l



**5 - Ultrafiltration module**  
 Plate membrane: 3.5 m<sup>2</sup>, pore size: 38 nm



**6 - Permeate**  
 Treated brownwater, COD: ~ 18 mg/l



# Brownwater treatment (MBR)

## 1 Technology

Source of brownwater:	38 Urine diverting flush toilets (Model NoMix, Roediger Vacuum)
Brownwater inflow <sub>average</sub> :	2000 l/d
Flowrate of permeate <sub>average</sub> :	350 l/d (Difference to the total daily brownwater inflow is discharged via the sewer system)

### 1.1 Volume

Pretreatment tank:	400 l
Membrane bioreactor <sub>average</sub> :	670 l

### 1.2 Pretreatment

Hole size in the screenbasket:	3 mm
Screen rotation <sub>day</sub> :	15 s operation, 60 s break
Screen rotation <sub>night</sub> :	15 s operation, 3600 s break
Flushing of screen:	10 s inflow, 10 s break, 10 s outflow (10 times/24h)
SS in filtrate:	400 - 450 mg/l

### 1.3 Membrane filtration module

Type of membrane:	Plate membrane (MembranClearBox ®)
Membrane surface & pore size:	3.5 m <sup>2</sup> , 38 nm
Material of membrane:	PES (Polyethylensulfone)
Scouring air <sub>regular</sub> :	continuously
Scouring air <sub>energy saving</sub> :	60 s operation, 60 s break
Aeration <sub>regular</sub> :	60 s operation, 60 s break
Aeration <sub>energy saving</sub> :	60 s operation, 360 s break
Oxygen concentration:	7.3 mg/l
MBR feeding pump:	Automatically regulated according to filling level of MBR
Permeate pump:	21 h/d filtration: 120 s operation, 60 s break 3 h/d relaxation (no operation)
Operation of permeate pump <sub>overall</sub> :	21 h/d
Operation of permeate pump <sub>net</sub> :	14 h/d (taking breaks into account)
Flowrate of permeate:	25 l/h; equivalent 350 l/d (14 h of operation)
Transmembrane pressure <sub>net</sub> :	
➤ average	-50 mbar
➤ maximum possible	-350 mbar
Flux <sub>net</sub> :	(Flow rate of permeate through membrane)
➤ average	7.1 l/(h x m <sup>2</sup> )
➤ maximum possible	30 l/(h x m <sup>2</sup> )
Concentration of activated sludge:	4 - 6 g/l TS
Removal of excess sludge:	15 l/week (automatically)

# Brownwater treatment (MBR)

## 1.4 Differences in operation of grey- and brownwater treatment

Apart from the pretreatment, the grey- and brownwater plants are technically similar. However, due to different characteristics of the influent the operation differs accordingly:

	Permeate pump	Permeate flowrate
Greywater treatment	270 s operation; 120 s break	23 l/h
Brownwater treatment	120 s operation; 60 s break	25 l/h

## 2 Analyses\*

	COD (mg/l)	N <sub>total</sub> (mg/l)	NO <sub>3</sub> -N (mg/l)	NH <sub>4</sub> -N (mg/l)	P <sub>total</sub> (mg/l)
Inflow <sub>after pretreatment</sub>	787 ± 200	70 ± 16	0.9 ± 0.3	0.6 ± 0.2	21 ± 6
Permeate	23 ± 4	76 ± 13	68 ± 10	0.04 ± 0.04	16 ± 5

\* Concentrations with 95% confidence intervals

	E. coli (n/100ml)	Intestinal enterococcus (n/100ml)	Coliform bacteria (n/100ml)
Permeate	37	28	535

COD- removal efficiency:  
97 %

Nutrient ratios in inflow:  
C : N : P = 100 : 9 : 0.9

## 3 Use of permeate

Possible areas of application:  
(Complying with quality standards e.g.  
EU Bathing water directive)

Process water for toilet flushing,  
heating, air conditioning, irrigation

Use in GIZ:

Due to technical reasons there is currently no reuse taking place.

## 4 Time spent on operation

The standard operation requires one scheduled maintenance event per year at which time an effluent sampling can also be analysed. Due to the research activities the time consumption is calculated as follows:

Maintenance:	2 days every six months
Analyses:	3 - 4 h/week
Checking the operation:	3 h (divided over two days per week)

## 5 Energy consumption

The energy consumption is mainly due to the plant component membrane bioreactor (see figure). These are design values, because no measures were done. The energy consumption can be higher than normal due to research activities.

Energy consumption:	1.2 kWh/d (equivalent to 455 kWh/a)
Specific energy consumption:	2.1 kWh/m <sup>3</sup>
Energy costs:	90 €/a (0.20 €/kWh)

## 6 Investment costs (without pretreatment)

Container, plant unit, control unit, membrane module	5,990 € (net, ex factory)
---	---------------------------



## Project partners (all in Germany)

**Deutsche Gesellschaft für Internationale Zusammenarbeit (GIZ) GmbH**  
Sustainable sanitation – ecosan program  
Dag-Hammarskjöld-Weg 1-5  
65760 Eschborn

**HUBER SE**  
Industriepark Erasbach A1  
92334 Berching

**RWTH Aachen**  
Institute for Environmental Engineering (ISA)  
Institute of Sociology (IfS)  
52056 Aachen

**Roediger Vacuum GmbH**  
Kinzigheimer Weg 104-106  
63450 Hanau

**THM University of Applied Sciences**  
Wiesenstraße 14  
35390 Gießen

**University Bonn**  
INRES - Department of Plant Nutrition  
Karlrobert-Kreiten-Strasse 13  
53115 Bonn

## Contact

**Deutsche Gesellschaft für Internationale Zusammenarbeit (GIZ) GmbH**  
Sustainable sanitation – ecosan program  
Dag-Hammarskjöld-Weg 1-5  
65760 Eschborn, Germany

Dr.-Ing. Martina Winker  
E-mail: [martina.winker@giz.de](mailto:martina.winker@giz.de) / [saniresch@giz.de](mailto:saniresch@giz.de)  
Phone: +49 (0)6196-79 3298

## Further project information

<http://www.saniresch.de/en>  
[www.facebook.com/saniresch](http://www.facebook.com/saniresch)

## Imprint

MAP factsheet:	Martina Winker, Amel Saadoun Updated on: 31.07.2012
Greywater factsheet:	Martina Winker, Amel Saadoun, Fanny Kilian Updated on: 31.07.2012
Brownwater factsheet:	Enno Schröder, Martina Winker, Fanny Kilian Updated on: 31.07.2012