




# CLARA : South Africa Pilot

- Capacity-linked water supply and sanitation improvement for Africa's peri-urban and rural areas

16<sup>th</sup> October 2013

Valerie Naidoo (Water Research Commission)  
Marlene vd Merwe-Botha (Watergroup)  
Gary Quilling (Watergroup)  
Solly Manyaka (Kaleo Consulting)  
eThekweni Municipality (Teddy Gounden)



# Outline



- ✓ Background : Selection of Sites (eThekweni Municipality)
  - ✓ Case study 1: Frasers settlement
  - ✓ Case study 2: Sarasvathi School
- ✓ Input to Simplified Planning Tool
  - ✓ Case study 1: Frasers settlement
  - ✓ Case study 2: Sarasvathi School
- ✓ Results
- ✓ Conclusions



# Background: Site Selection



© www.places.co.za



# Background : Selection of Sites



Fraser  
(ethekwini




Fraser  
Informal  
Settlement



Sarasvati  
Primary  
School

# Case study 1: Fraser Settlement (eThekweni)

- ✓ Peri-urban(informal)
- ✓ PE 1000
- ✓ Water supply available
- ✓ Sensitive environment
- ✓ High unemployment (46%)
- ✓ Low income
- ✓ Agriculture based
- ✓ Low education levels




## FRASERS

### Legend

- Wards
- Plan Unit
- Fraser's
- Informal Settlement\_Nov11
- dwellings 20091126 v02 selection
- educational\_institutions
- roads
- WATERMANS
- Rivers

Disclaimer Notice  
The eThekweni Municipality accepts no liability or responsibility whatsoever for the correctness of and/or accuracy of this information. In the case of Council Services, it must be used as a guide only. Data should be physically checked on site.



# 1. Testing the Tool: Fraser Settlement



Existing water services	Alternatives assessed
Pressure water supply from Umgeni water scheme from Hazelmere WPW via 300 mm dia pipeline at 6 kPa, gravity line with PRVs. Water offtake via 75 and 50mm uPVC. Class A quality water	No alternatives assessed.
5 standpipes and 5 CABs services 96.6% of population, boreholes the rest	Umgeni plan to upgrade the 300mm to 1m dia pipe, drawing from WPW.
Existing sanitation services	Alternatives assessed
1 = CABs and onsite waterborne septic tank & ABR	2 = CAB linked to offsite centralised waterborne sewer system



## Input constants for Alternative 1 & 2:

- Period of consideration: 50 years
- Net interest rate: should be 8.5%
- Expected annual growth: 1.8%

# Example of process flow diagram : ALT 1 & ALT 2



# FRASER TECHNOLOGIES INVESTIGATED



## ALTERNATIVE 1 = CABs and onsite waterborne sanitation (CABS + SepticTank + ABR)



### Wastewater collection:

- **Technology 1: Sewer for CAB A-B**

- PE 200, trench depth 0.8m, sewer length 66 – 78 m, depending in CAB

- **Technology 2: collection of faecal sludge**

- 5 pick up points, 1x annum, 5 m<sup>3</sup>/a



### Wastewater treatment:

- **Technology 1: Septic tank for CAB A-E**

- PE 200, 1x tank 6mx3mx2m

- **Technology 2: ABR for CAB A-E**

- 1x ABR 6mx3mx2m





# FRASER TECHNOLOGIES INVESTIGATED



## ALTERNATIVE 2 = CABs and centralised waterborne sanitation (CAB's + sewer (to existing WWTP))



### Wastewater collection:

- **Technology 1: Sewer for CAB A-B**

- PE 200, trench depth 1.2m, sewer length 283 – 560 - 700m, depending in CAB

- **Technology 2: Sewage pump station**

- Flow 1.2 m<sup>3</sup>/h, 56 pressure head (actual is 6m but tool require +50 factor)

- **Technology 3: Sewer**

- PE 400 for 2 CAB inputs, trench depth 1.2m, length 700m

*etc up to Technology 6.*




# Results from SPT: Fraser Settlement




	Alternative Name	Investment Costs	Σ Reinvestment Costs	Σ O/M Costs	Σ Revenues	Total Costs/Profits	Final Residual Values
1	Current - CAB and on-site sanitation: Sewerage Collection to septic tank & ABR	€ 533 773	€ 3 093 346	€ 2 925 743	€ 0	€ 4 631 573	€ 293 589
2	Future - CAB are linked to waterborne system	€ 204 812	€ 403 278	€ 512 387	€ 0	€ 851 048	€ 71 428

## Cost distribution of alternatives



# Results from SPT: Fraser Settlement



- ✓ Current selected option of on-site sanitation not feasible as a permanent service option over 50 year lifespan : conventional service provision more feasible and one has to make the decision with the following considerations:
  - ✓ Informal
  - ✓ Private land
  - ✓ Subsidised service

# Case study 2: SARASVATHI SCHOOL (eThekweni)



- ✓ Primary school
- ✓ 325 learners, 10 educators
- ✓ Public school on private land
- ✓ No agreement.
- ✓ School serves impoverished community (mainly of migrant labourers,
- ✓ Have basic water and sanitation services.



# Site 2: Testing the Tool: SARASVATHI



Existing water services	Alternatives assessed
<p>1 = Same pressured, unmetered supply ; Two standpipes, 4 taps at water troughs supply at 10l/day (9 kl/month). Supply 350 people with Class 0 water.</p>	<p>2 = Equip rainwater harvesting tanks to augment existing service. (possibility)</p>




Existing sanitation services	Alternatives assessed
<p>1 = 3 ablution buildings, 8 toilets, uPVC pipe of 12m 110mm feeds to 2 septic tanks which are emptied every 2-18months, 30 learners/toilet</p>	<p>2 = Tamper resistant ablution with 12 toilets, network to ABR // septic tank / leach fields</p> <p>3 = Sludge drying &amp; reuse, compost, biogas</p>



## Input constants for alternatives:

- Period of consideration: 30 years
- Net interest rate: should be 8.5%
- Expected annual growth: 0% (no plan to expand school)

# Example of process flow diagram : ALT 1, & 3



# SARASVATHI TECHNOLOGIES INVESTIGATED



## ALTERNATIVE 1 = ablution and septic tanks

### Wastewater collection:

- **Technology 1: Sewer**

  - PE 350, trench depth 0.8m, sewer length 12m

- **Technology 2: Cesspit**

  - PE 350, discharge black & grey water from ablution facilities only

- **Technology 3: Collection of faecal sludge**

  - 1x 5000l tanker used, discharge to Tongaat WWTW every 12-24months, 5m<sup>3</sup>/pick up, 12km distance

### Wastewater treatment:

- **Technology 1: Septic tank**

  - PE 350, 2x tanks (6mx3mx2m)



## ALTERNATIVE 2 = ablution and septic tanks/ABR

### Wastewater collection:

- **Technology 1: Sewer**

- PE 350, trench depth 0.8m, sewer length 140m

- **Technology 2: Cesspit**

- PE 350, discharge black & grey

- **Technology 3: Collection of faecal sludge**

- 1x 5000l tanker, discharge to Tongaat WWTW every 12-24months, 5m<sup>3</sup>/pick up, 12km distance

### Wastewater treatment:

- **Technology 1: ABR**

- PE 350, 1x reactor (6mx3mx2m)

- **Technology 2: Septic tank**

- PE 350, 1x reactor (6mx3mx2m)





## ALTERNATIVE 3 = resource-oriented

### Wastewater collection:

- **Technology 1, 2, 3** same as per Altern. 2: **Sewer/Cesspit/Sludge**



### Wastewater treatment:

- **Technology 1: ABR**

• PE 350, 1x reactor (6mx3mx2m), 80% removal rate



- **Technology 2: Septic tank**

• PE 350, 1x reactor (6mx3mx2m), emptied 1x/24months



- **Technology 3: Sludge dewatering**

• Sludge volume 4.2m<sup>3</sup>/d, TS 5%, anaerobically stabilised, sludge volume 1540m<sup>3</sup>/a



- **Technology 4: Composting beds**


• Faeces from UDDTs 0 (N/A), 0.84m<sup>3</sup>/d dewatered sludge, biowaste N/A



# Results from SPT: Sarasvati School




	Alternative Name	Investment Costs	Σ Reinvestment Costs	Σ O/M Costs	Σ Revenues	Total Costs/Profit	Final Residual Values
1	Historic on-site Sanitation	€ 621 455	€ 676 519	€ 314 533	€ 0	€ 1 273 559	€ 201 585
2	Current Sanitation	€ 648 786	€ 695 130	€ 315 900	€ 0	€ 1 320 301	€ 211 972
3	Resource Orientated option	€ 730 657	€ 777 619	€ 406 392	€ 86	€ 1 533 745	€ 235 466



	Historic on-site Sanitation	Current Sanitation	Resource Orientated option
Σ Revenues	€ 0	€ 0	-€ 86
Σ O/M Costs	€ 314'533	€ 315'900	€ 406'392
Σ Reinvestment Costs	€ 676'519	€ 695'130	€ 777'619
Investment Costs	€ 621'455	€ 648'786	€ 730'657

# Results from SPT: Sarasvati School



- ✓ cost progressively increases with adding of additional service options
- ✓ historical situation had deteriorated and needs to be upgraded to comply
- ✓ resource orientated option does not generate substantial revenue:
  - ✓ Impact negligible
  - ✓ If risks managed could have value around “living lab” concept
  - ✓ Linking to biogas and crop production

# Conclusions



- Tool is ambitious, but will give good 1<sup>st</sup> order base to inform decisions on system options
- Gives clear difference for distinctive system options:
  - Decentralised waterborne
  - Centralised waterborne options
- For on-site systems – where changes are incremental due to addition of unit processes to meet specific performance improvements and services, the additional cost may be less significant over the life-cycle.
- Finally, by testing the following options, it allows one to think about the options tested under the specific assumptions and refine and test further.



# THANK YOU



## Acknowledgements

The work is carried out within the project CLARA (Capacity-Linked water supply and sanitation improvement for Africa's peri-urban and Rural Areas; Contract # 265676; duration: 1.3.2011 – 28.2.2014; <http://clara.boku.ac.at/>), a Collaborative Project funded within the EU 7th Framework Programme, Theme "Environment"



Capacity-Linked water and sanitation  
for Africa's peri-urban and Rural Areas

