

# Vacuum Sewerage and Greywater treatment

## Experience of 8 years of operation

**Martin Oldenburg**  
**Andrea Albold**

Infranova GmbH&Co KG  
Flintenbreite 4  
23554 Lübeck  
[www.flintenbreite.de](http://www.flintenbreite.de)

**OtterWasser**  
GmbH

Ingenieurgesellschaft  
für integrierte  
Siedlungstechnik  
Engelsgrube 81  
D-23552 Lübeck  
☎ (+49) 0451-70 200-51  
-52  
✉ [info@otterwasser.de](mailto:info@otterwasser.de)  
[www.otterwasser.de](http://www.otterwasser.de)

[www.otterwasser.de](http://www.otterwasser.de)


**Ralf Otterpohl**  
Institute for Wastewater Management and Water Protection  
Hamburg University of Technology (TUHH), Germany

# Project's History

- Residential area in the city of Luebeck ( $A_{\text{tot}} = 5.4 \text{ ha}$ )
- Private operating infrastructure company  
(operation of wastewater treatment system and operation of all other medias supplying the houses)
- Project started in 1999 designed for 117 units
- Interruption at 30 units in 2000
- Operation of the infrastructure systems since 8 years

# Current Situation

- Infrastructure is mainly finished
- 23 terraced houses  
12 twin houses  
Central building with 4 flats
- 116 inhabitants
- All facilities for the technical operation are finished and in operation since 2000
- Ongoing:  
Construction of 42 terraced houses and 12 flats



# Flintenbreite







# Characteristics

- Buildings designed as low energy consuming houses
- Ecological materials have impact on energy and material flows during buildings life cycle
- All consumption data of the houses are known because of the installation of meters
  
- Infrastructure system is operated by a private company and recharged by fee calculations
  
- Here focus only on water and wastewater related issues.


# Sanitation concept



# Water consumption per unit



# Water consumption per capita





# Composition of greywater

|                |                    | Influent         |                 | Effluent  |                 |           |
|----------------|--------------------|------------------|-----------------|-----------|-----------------|-----------|
| Parameter      | Unit               | Average          | Range (min-max) | Average   | Range (min-max) |           |
| Volume         |                    | L/(cap•d)        | <b>60</b>       | 50 - 120  |                 |           |
| Organic matter | BOD <sub>5</sub>   | g/m <sup>3</sup> | <b>156</b>      | 136 – 194 | <b>6</b>        | 1 – 14    |
|                | COD                | g/m <sup>3</sup> | <b>426</b>      | 258 – 584 | <b>41</b>       | 6 – 73    |
| Nutrients      | N                  | g/m <sup>3</sup> | <b>11</b>       | 8 – 17    | <b>3.6</b>      | 1.2 – 5.7 |
|                | P <sub>tot</sub>   | g/m <sup>3</sup> | <b>6.2</b>      | 4 – 10    | <b>4.5</b>      | 1.2 – 6.8 |
|                | PO <sub>4</sub> -P | g/m <sup>3</sup> | <b>5.0</b>      | 3 - 8     | <b>3.9</b>      | 2.8 – 5.1 |



# Sludge from greywater

- Greywater contains sludge
- Solid removal important for biological treatment
- Colour:  
upper part: white – grey  
lower part: dark
- Sludge volume:  
approx.  
42 l/(cap\*a)
- Desludging  
interval:  
5 – 6 years



# Composition of blackwater

| Parameter      | Unit               | Average          | Range (min-max) |                |
|----------------|--------------------|------------------|-----------------|----------------|
| Volume         | L/(cap•d)          | <b>6</b>         |                 |                |
| Organic matter | COD                | g/m <sup>3</sup> | <b>10,496</b>   | 3,640 – 29,230 |
|                | TC                 | g/m <sup>3</sup> | <b>3,716</b>    | 1,820 – 7,821  |
|                | MLSS               | g/m <sup>3</sup> | <b>9.0</b>      | 3.5 – 23.9     |
|                | VSS                | %                | <b>66</b>       | 45 – 63        |
| Nutrients      | N <sub>tot</sub>   | g/m <sup>3</sup> | <b>1,505</b>    | 1,050 – 1,920  |
|                | NH <sub>4</sub> -N | g/m <sup>3</sup> | <b>1,081</b>    | 790 - 1,510    |
|                | P <sub>tot</sub>   | g/m <sup>3</sup> | <b>202</b>      | 98 - 377       |




# Elements of vacuum system

- Vacuum toilet
- Vacuum pipe (Ø 40 - 50 mm)
- Temporary Buffer storage (8 L)
- Vacuum pipe (Ø 50 – 63 mm)
- Vacuum station






# Operation Vacuum System



# Energy consumption Vacuum



# Operation vacuum system

- Blockage caused by misuse mainly in the beginning of the operation
  - Flush button accident-sensitive
  - Clogging of air control tubes with fibres
  - Temporary buffer store equipped with bypass meanwhile
  - Toilet valves have higher lifetime than expected
  - Pipes has to be cleaned with acid after 6 years of operation to remove blockades caused by hardness precipitation
  - Monitoring of energy consumption of vacuum station can identify air leakages
- 
- All maintenance is done by staff of the operation company not by the residents.

# Lessons learned



- Temporary buffer storage is not necessary
- High ammonia concentrations can be noticed by opening of the pipe system
- Treatment of exhausted air necessary (biofilter)
- PE-pipes for vacuum pipes recommended  
no steel or galvanised steel pipes (cleaning may hurt inner surface and makes corrosion possible)  
high ammonia concentrations may cause corrosion
- Because of high water hardness regular treatment of pipes with acid is necessary (every 5 – 6 years)
- Energy consumption for vacuum: 45 kWh/(cap\*a)



# Volumes and loads of Grey- and Blackwater

**Blackwater**  
5 l/(Pers\*d)

**Greywater**  
65 l/(Pers\*d)



# Conclusion

- Source separation very effective
- Most of the inhabitants recognize the benefits of the vacuum toilet-system; development of the toilets is wanted
- Experience may decrease the effort for maintenance
- Minor technical modifications of the vacuum system have been necessary
- Operation costs of integrated infrastructure system approx. 20 % lower than for conventional system