



SFD Lite Report

Barguna Municipality Bangladesh

This SFD Lite Report was prepared by
CWIS-FSM Support Cell, DPHE

Date of production/ last update: 22/09/2022

1 The SFD Graphic




Figure 1: SFD Graphic for Barguna Municipality.

2 SFD Lite information

Produced by:

- Dr. Abdullah Al-Muyeed, Chief Operating Officer, CWIS-FSM Support Cell, Shishir Kumar Biswas, Project Director, 'Feasibility for Implementing of Solid Waste and Faecal Sludge Management System in 53 District Level Municipalities and 8 City Corporations', Department of Public Health Engineering (DPHE) and Md. Tawhidur Rahaman, Technical Expert, CWIS-FSM Support Cell, Department of Public Health Engineering (DPHE), Bangladesh.

Collaborating partners:

- DevCon, Tiller and Barguna municipality played vital roles in collecting and sharing data, and producing this SFD graphic and SFD lite report.

Date of production: 22/09/2022

3 General city information

Barguna is a fast-growing city, which is 319 km away from the Dhaka city. It is beside the Khakdon River and well connected with road and water. It is one of the oldest towns in the sub-continent and was declared municipality in 1973. Barguna is one of the 53 district level municipality in the country (Figure 2).

Table 1: City profile (Source: KII with the Executive Engineer, Barguna Municipality).

Population parameters	
Estimated population, 2020	40,543
Households, 2020	8,968
Area, sq.km	15.57
Total roads, km	172
Total drains, km	67




Figure 2: Barguna Municipality Location Map (BBS/ GIS report 2017).

According to the population census in 2011 by the Bangladesh Bureau of Statistics (BBS), the Barguna municipality population was 32,235. The urban population growth in Barguna is 1.50% per year. Considering 10% floating population, such as farmers and traders, comes to the city every day, the present (2020) population is estimated to be around 40,543 (Table 1).




Figure 3: Barguna Municipality Ward Boundary Map (BBS/ GIS report 2017).

The municipality covers an area of 15.57 square kilometres. At present Barguna municipality has 172 km of road network and 67 km of drain network¹. The geographical coordinates of Barguna are 22°5'43.05" N, 90°6'43.45" E². In the context of Bangladesh, the municipality area is almost flat and the area is relatively low land (Figure 3).

¹ Source: 'At a Glance: Barguna Municipality', by municipal office

² <https://www.latlong.net/place/Barguna-bangladesh-13499.html>

According to the Bangladesh Meteorological Department (1981-2017)³, the city area and surrounding area experience a tropical monsoon climate. It is characterized by warm, humid summers and cool, and dry winters. There is no climatological station within the municipality. The closest meteorological station of Bangladesh Meteorological Department is located in Khepupara which is about 32 km away from the municipality area. Weather data from this station were collected from 1981 to 2017. About 90% of the total annual rainfall occurs in the period from May through October and the driest months of the years are November to March. The maximum mean temperature observed is 30.5-32.6°C between April-August, with the minimum mean temperatures are found between 13.9-15.4°C in December-January. The annual average rainfall is about 2,764 mm, according to BMD (1981-2017).

Barguna Municipality is situated on the bank of Khakdon River. Bishkhali River passed 4.8 km away from the municipality. Several *khal* passed the northern-eastern side of the municipality. According to the flood zoning map of Bangladesh, the municipality is in a flood-free zone (in the last 12 years no flooding event happened) but the municipality is situated in riverbank erosion prone area. However, the drainage network of the city is not adequate⁴. Every year, municipality areas face water logging during monsoon for drainage congestion. There are some secondary drains carrying stormwater and domestic wastewater to the outfalls of the rivers and canals. The population density is high in the north-west, ranging from 12,001 to 15,491 per sq km. The population density in the centre and south-east is lower, ranging from 414- to 3,000 per sq km⁵.

³ <http://bmd.gov.bd/p/Rainfall-Situation-202>

⁴ *KII and field visit during Baseline survey 2020*

⁵ *KII and field visit during Baseline survey 2020*

4 Service outcomes

Barguna Municipality, Barguna, Bangladesh , 19 Sep 2022. SFD Level: SFD Lite								
Population: 40543								
Proportion of tanks: septic tanks: 82%, fully lined tanks: 0%, lined, open bottom tanks: 100%								
Containment								
System type	Population	WW transport	WW treatment	FS emptying	FS transport	FS treatment	SN transport	SN treatment
	Pop	W4c	W5c	F3	F4	F5	S4e	S5e
System label and description	Proportion of population using this type of system (p)	Proportion of wastewater in open sewer or storm drain system, which is delivered to treatment plants	Proportion of wastewater delivered to treatment plants, which is treated	Proportion of this type of system from which faecal sludge is emptied	Proportion of faecal sludge emptied, which is delivered to treatment plants	Proportion of faecal sludge delivered to treatment plants, which is treated	Proportion of supernatant in open drain or storm sewer system, which is delivered to treatment plants	Proportion of supernatant in open drain or storm sewer system that is delivered to treatment plants, which is treated
T1A1C6 Toilet discharges directly to open drain or storm sewer	3.7	0.0	0.0					
T1A2C5 Septic tank connected to soak pit	13.7			47.0	0.0	0.0		
T1A2C6 Septic tank connected to open drain or storm sewer	15.2			24.0	0.0	0.0	0.0	0.0
T1A2C7 Septic tank connected to open water body	6.0			24.0	0.0	0.0		
T1A2C8 Septic tank connected to open ground	6.5			24.0	0.0	0.0		
T1A2C9 Septic tank connected to 'don't know where'	0.3			24.0	0.0	0.0		
T1A4C10 Lined tank with impermeable walls and open bottom, no outlet or overflow	1.7			57.0	0.0	0.0		
T1A5C10 Lined pit with semi-permeable walls and open bottom, no outlet or overflow	52.9			71.0	0.0	0.0		

Table 2: SFD Matrix for Barguna Municipality.

The outcome of the SFD graphic shows that only twenty four percent (24%) of the excreta flow is classified as safely managed, and the remaining eighty percent (76%) is classified as unsafely managed (Figure 1). The unsafely managed excreta originate from wastewater not delivered to treatment (4%), Faecal Sludge (FS) both contained and not contained - not delivered to treatment (49%), FS not contained - not emptied (20%) and 3% of supernatant not delivered to treatment. Thus, the safely managed excreta originate from FS contained - not emptied (24%).

The percentages presented in Table 2 and discussed in the next section are based on data collected through household (HH) surveys, Key Informant Interviews (KIIs) and Focus Group Discussions (FGDs) (Figure 4).

Overview on technologies and methods used for different sanitation systems through the sanitation service chain is as follows:

4.1 Offsite Systems

The city does not have a dedicated sewerage system. However, during field observation and HH survey, it was found that there is a certain area where toilets are directly connected to open drains or storm sewer. Similarly, a portion of septic tanks is directly connected to open drains or storm sewer. Therefore, T1A1C6 system is considered as 3.7% of the total population of the city to generate the SFD graphic. Similarly, the T1A2C6 system is considered 15.2% of the total population of the city to generate the SFD graphic. In the absence of a sewerage system, the wastewater in T1A2C6 and the supernatant in T1A2C6 are directly discharged into the river or the environment untreated.

4.2 On-site Sanitation Systems



Figure 4: Household survey and consultations. Left: Household survey. Right: Consultation meeting (Source: Feasibility study 2020-21/DPHE).

Containment: Almost all the households (98%) in the city have their latrine which is connected to single pits, twin pits, septic tanks, or discharged directly into the environment (e.g., open-drain or storm sewer). The rest of the households use community latrines (2%). From the household survey, it was found that 41.7% of the city population uses septic tanks as the containment system, 52.9% of the toilets have single pit systems, and 1.7% of people use double pits in the city. About 3.7% do not have any type of containment and discharges directly to the environment (KII, FGDs, HH survey, 2020).

According to the type of connectivity and features of containment technologies, the discharging points of the toilets are categorized as: 13.7% of the population uses septic tanks connected to soak pits (T1A2C5), 15.2% of the population uses septic tanks connected to open drain (T1A2C6), 6.0% of the population uses septic tanks connected to water bodies (T1A2C7), 6.5% of the population uses septic tanks connected to open ground (T1A2C8), 0.3% of the population uses septic tanks connected to 'don't know where' (T1A2C9), 1.7% of the population uses lined tanks with impermeable walls and open bottom no outlet or overflow (T1A4C10) and 52.9% of the population relies on lined pits with semi-permeable walls and open bottom with no outlet or overflow (T1A5C10) (KII, FGDs, HH survey, 2020). Thus, at the containment stage, the city's excreta of only 68% of the population are contained. Figure 6 shows pictures of these technologies in operation.

Groundwater Pollution: The depth to groundwater in the city ranges from 1-3 m. There are various drinking water sources used in the city. Among them, 10% of the population use tubewell fitted with electric motor, 10% use own hand pump tube well, 9% use supply water and 71% depends on other sources. Lateral separation between sanitation facilities and water sources varies from one area to another. Tube wells of different sizes and depths are generally used to pump water from the subsurface confined aquifers (Figure 5).




Figure 5: Soil profile in Barguna district and location of tube well screen.

During the household visit and FGDs, it was found that less than 25% of sanitation facilities are located within 10 metres from the groundwater source. Besides, due to the geographical situation, sanitation facilities are not located uphill of the groundwater sources. According to a survey report on ‘Hydrogeological screening, slug test and geophysical logging on observation well units’, conducted by the Department of Public Health Engineering (DPHE) on March 2017, drinking water is collected from the confined aquifer (25m – 200m) through pumps. Hence, considering all these factors, it is considered that there is not any significant risk of groundwater contamination in the city. Therefore, a low risk of groundwater contamination is considered in the city.



Figure 6: Containment technologies and their connections in Barguna
Left: Toilet pit open to a nearby water body, Right: Toilet pipe connected to open environment
 (Source: Feasibility study 2020-21/DPHE).

Emptying: Households relying on septic tanks have to arrange themselves for emptying of the septic tank. It was observed from the baseline survey that most of the septic tanks have been constructed in the last 4-6 years. According to the survey from 2020, the frequency of emptying of septic tanks or covered pits varies from 1 to 10 years depending upon the size, uses, etc.

However, about 47% of the septic tanks, connected to the soak pit are emptied within 2-5 years. About 24% of the septic tanks connected to open drains, open ground or water bodies are emptied within 4-5 years. Almost 71% of single pit latrines are emptied within 1-2 years. Besides the above information, it was also revealed during the discussion in FGDs and household visits that the demand for desludging septic tanks would increase shortly. Desludging of the septic tanks or pits is mostly (97%) done by private sweepers. Only in a few households, desludging is done by municipal sweepers (2%) or family members (1%). Around 90% of this withdrawal is done manually using a bucket and rope. This method highly risks the health and safety of the workers. A substantial number (10%) use electric pumps, these reflecting the use of the higher level of technologies by some of the workers. Manual emptying is the common practice in this city.

Transportation: The sludge withdrawn from the septic tanks and latrine pits by the cleaners is disposed of in various places. Based on the survey from 2020, it was observed that about 67% of the respondents who use any kind of containment system informed that faecal sludge (sludge from the septic tanks or covered pit latrines) is disposed of in a dug hole covered with soil away from the house. Besides, 33% of the faecal sludge is disposed of in the open environment like a drain, open ground, and water bodies.

Treatment/Disposal: There is one under construction FS treatment plant in Barguna.

4.3 Open Defecation:

From HH surveys, KIIs and FGDs, it was found that 100% of citizens use some kind of toilet in the municipality. Thus, from the sanitation point of view, the town is considered an open defecation-free town.

5 Data and assumptions

The baseline survey conducted in September 2020 contains detailed data on different stages of the sanitation value chain. The SFD matrix is generated from these data, collected during sample household surveys, along with informal interviews, open-ended consultations, key informant interviews and focus group discussions with the municipality officials, town level coordination committee, households, social workers, business persons, pit emptiers and the citizens including women in all the wards of the municipality. The SFD matrix was generated from these data. Finally, data from all these sources were triangulated to produce the SFD matrix, the SFD graphic and the SFD lite report.

The last census was carried out about 10 years ago. So, the actual population, household, and sanitation data are not updated yet. Most of the households with septic tanks do not know the actual type, size, and design desludging periods. Also, a large number of pit users are unaware of the emptying events and frequency of their pits or not. Due to all these data gaps, some assumptions have been made to produce the SFD graphic. These assumptions were shared with key informants at the municipality and accepted by them.

Following assumptions were made for developing the SFD graphic for Barguna municipality:

- ✓ The proportion of FS in septic tanks, fully lined tanks, and lined, open bottom tanks are considered 82%, 0%, and 100% respectively as per the guidance given in the Frequently Asked Questions (FAQs) in the Sustainable Sanitation Alliance (SuSanA) website.
- ✓ According to the population census in 2011 by the Bangladesh Bureau of Statistics (BBS), the population of Barguna Municipality was 32,235. The urban population growth in Barguna is 1.5% per year. Considering 10% floating population, such as farmers and traders, comes to the city every day, the present (2020) population is estimated to be around 40,543.
- ✓ There are around 1.7% of twin pit latrines in the containment system. So, it is assumed that all these twin pit containment technologies are defined as a lined tank with impermeable walls and open bottom (system T1A4C10, 1.7%). Based on the household survey, variable F3 for system T1A4C10 was set to 57%.
- ✓ There are around 52.9% of single pit latrines in the containment systems. So, it is assumed that all these single pit containment technologies are defined as lined pits with semi-permeable walls and open bottom, no outlet or overflow, where there is no 'significant risk' of groundwater pollution (system T1A5C10, 52.9%). Most of the single pit latrines are found to be emptied within 1-2 years. Based on the household survey, variable F3 for system T1A5C10 was set to 71%.
- ✓ 13.7% of septic tanks are connected to soak pits (system T1A2C5). They are well-constructed as per the field visit observation. The risk of groundwater contamination was deemed low, therefore that option was selected in the SFD Matrix.
- ✓ Around 47% of HHs have emptied their septic tank with a soak pit with a desludging frequency of 2-5 years. Based on the household survey, variable F3 for system T1A2C5 is set to 47%.
- ✓ There are 28% of septic tanks connected to the open drain, water bodies, open ground and 'don't know where which are emptied within 2-5 years. Based on the household survey, variable F3 for systems T1A2C6, T1A2C7, T1A2C8 and T1A2C9 are set to 24%.
- ✓ Wastewater in T1A1C6 and supernatant in T1A2C6 are directly discharged into the river or the environment untreated. Therefore, variables W4c, W5c, S4e and S5e were set to 0%.
- ✓ Since there are no wastewater or faecal sludge treatment facilities in the town and all the collected FS is disposed untreated into the environment, variables F4 and F5 for all systems are considered to be 0%.

6 List of Sources

Reports, literature and website

- Bangladesh Bureau of Statistics (BBS), 2011.
- Population and Housing Census, 2011.
- Baseline Survey of the project “Feasibility for Implementing of Solid Waste and Faecal Sludge Management System in 53 District Level Municipalities and 8 City Corporations”, Department of Public Health Engineering (DPHE), Dhaka, Bangladesh (December 2020).
- Report on ‘Hydrogeological Screening, Slug Test and Geophysical Logging on Observation Well Units’ under *Bangladesh Rural Water Supply and Sanitation Project (BRWSSP)*, Arsenic Management Division, Department of Public Health Engineering (DPHE) (March 2017)
- The revised ‘National Strategy for Water Supply and Sanitation, 2021’
- ‘At a Glance: Barguna Municipality’, by municipal office.
- <https://www.gps-latitude-longitude.com/gps-coordinateshttp://bmd.gov.bd/p/Rainfall-Situation-202>

Key Informant Interviews (KIIs) (September 2020 to December 2020)

- KII with Mayor, Barguna Municipality.
- KII with Conservancy Inspector, Barguna Municipality.
- KII with Sanitary inspector, Barguna Municipality.
- KII with Engineer, Barguna Municipality.
- Facilitators: Md. Mynul Islam Hemel, Field Coordinator, Tiller.



Figure 7: KIIs with different stakeholders in Barguna. (Source: *Feasibility study 2020-21/DPHE*).

Focus Group Discussions (FGDs) (September 2020 to December 2021)

- FSM Sweepers and Service Providers.
- First Stage Solid Waste Collector.
- Slum Dwellers.



Figure 8: Focus Group Discussions in Barguna. (Source: *Feasibility study 2020-21/DPHE*).

Additional information

- This report was compiled as part of the Baseline Survey of the project, ***“Feasibility for Implementing of Solid Waste and Faecal Sludge Management System in 53 District Level Municipalities and 8 City Corporations”***, (December 2020).
- The project was implemented under the supervision of the Department of Public Health Engineering (DPHE). In-depth information and data were collected for the towns which included project documents, master plans and baseline reports from the municipality and national levels, statistical data like population and household income expenditure, GIS data and other geospatial data and satellite images, and open street maps (OSM). The Field Survey of the project was conducted from 01 January 2020 to 24 March 2020 and from 04 July 2020 to 30 November 2020. The field survey includes household surveys, key informant interviews, focus group discussions, and physical feature surveys. A central server has been established to monitor FSM and SWM databases under the project. The results of the study are shared with the municipal authority and are considered as a basis for preparing investment projects by the government and development partners, and sustainable plans for operating and maintaining the systems by the municipal authorities.
- We would like to thank Mr. Advocate Kamrul Ahsan Moharaj, Mayor, Barguna Municipality, Mr. ATM Mohiuddin Khandkar, Executive Engineer, Barguna Municipality; Mr. Md. Rafiqul Islam, Secretary, MrMd. Kamal Hossen, Slum Development Officer, Barguna Municipality for providing all the required primary and secondary data and cooperating for Key Informant Interviews (KIIs) & Focused Group Discussions (FGDs). This report would not have been possible to produce without the constant support of Mr. Advocate Kamrul Ahsan Moharaj, Mayor, Barguna Municipality, who helped in conducting sample surveys and FGDs in the field.
- We also acknowledge the support of the Centre for Science and Environment, India for the promotion of SFD in Bangladesh.

Barguna Municipality, Bangladesh, 2022

Produced by:

Dr. Abdullah Al-Muyeed, Chief Operating Officer, CWIS-FSM Support Cell

Shishir Kumar Biswas, Project Director, Feasibility for Implementing of Solid Waste and Faecal Sludge Management System in 53 District Level Municipalities and 8 City Corporations, Department of Public Health Engineering (DPHE)

Md. Tawhidur Rahaman, Technical Expert, CWIS-FSM Support Cell

Department of Public Health Engineering (DPHE), Bangladesh

© Copyright

All SFD Promotion Initiative materials are freely available following the open-source concept for capacity development and non-profit use, so long as proper acknowledgement of the source is made when used. Users should always give credit in citations to the original author, source and copyright holder.

This SFD lite report is available from:
www.sfd.susana.org

SFD Promotion Initiative

